

# WEPROG

Weather & wind Energy PROGnosis

## Using Ensembles for Large-scale Forecasting of Wind Power in a European SuperGrid context

Corinna Möhrlein and Jess U. Jørgensen

**DEWEK 2010**  
**Session 10/P4**

Including physical Uncertainty from Ensembles

# **A Large Scale Wind Integration Study Using an artificial SuperGrid in the Western and Central part of Europe**

Questions to be answered:

- How does the frequency distribution of the generation look ?
- How well does wind power fit the large scale demand ?
- Which countries fit best together in a SuperGrid?
- What happens with respect to day-ahead predictability ?
- What happens with respect to reserve requirements ?
- How do we use fully loaded interconnectors for balancing ?
- Will a SuperGrid only be feasible with Offshore Wind ?

## Some Pros & Cons of a SuperGrid

- A larger market has some benefits, e.g. more competition
- Forecast errors and hence reserve requirements reduce
- Less fossil fuel plant will be required
- More coherent prices in a large area for consumers and generators
- Need of additional interconnectors and grid infrastructure
- Need of a Super-TSO, existing TSOs may have to give up some tasks
- A large grid is more complex to model

# Simulation of SuperGrid: Model Approach & Assumptions

## **Model Setup**

Capacity is accumulated in MSEPS model grid points

- 13 countries
- approximately 1400 grid points from 2260 registered wind farms and ca. 26000 wind turbines in Denmark and Germany
- power curves generated from public data in Germany, Denmark and Ireland

A consistent handling of all wind power is required:

- Use the same model estimate for verification in all countries (no measurements, will create slightly worse result for countries where measurements are available)
- Use 00UTC and 06UTC forecasts for day-ahead horizon

## **Model Assumptions**

- transmission capacity limits are ignore in this study
- existing shares/pools of wind power by different parties are ignored
- Capacity distribution from July 2010 kept constant over entire simulation period 2008/07-2010/07

## **Assumptions for Practical Integration of Approach:**


- Centralized balancing of Wind Power in pools shared in slices
- Fixed percentages of total generation given to each forecast provider
- A meta forecast is made based on all forecasters reports to the central unit

# Selection Criteria of Countries in the SuperGrid

- Driving forces in the weather should be similar (lows from Atlantic or north pole)
- Correlation with other country's generation (best range 0.40-0.95)
- Correlation > 0.4 good for cross country balancing ( <0.4 good for sale )
- Low competition on reserve (need of new means for balancing)
- Uniform distribution of capacity (especially extending to country borders)
- Future interconnection plans (ambitious plans considered good)
- Wind generation potential (a high potential is likely to be developed)
- Offshore Wind generation plans (offshore power and grid expansion)
- Current level of publication (required for verification of the approach)

**Selection:** 8 countries = BE, DE ,DK, FR,IE, NL, SE, UK = 440

# Country Selection



The **selected countries** are marked as green area, and:


- mostly **experience the same kind of weather** and have many common borders and the potential for more interconnections.
- **offshore expansion** in North Sea and Baltic Sea **will further connect the countries** to each other.
- Southern France and the north of Sweden are somewhat detached, but still included.

- Spain and France have very little capacity near the common boarder
- Italy has nearly all capacity far south
- The capacity in Norway and Finland is far north
- Austrian generation is concentrated near Hungary

==> Little possibility to exchange imbalance for these countries


# Correlation of Generation & Diurnal Generation Profile

SG	0.94													
ie	0.29	0.32												
de	0.88	0.95	0.17											
dk	0.67	0.74	0.21	0.68										
at	0.23	0.14	0	0.2	0.03									
be	0.72	0.77	0.28	0.63	0.34	0.04								
es	0.45	0.13	0.04	0.1	0.06	0.19	0.09							
fi	0.21	0.19	0.09	0.14	0.21	0.02	0.1	0.09						
fr	0.61	0.58	0.2	0.45	0.16	0.1	0.82	0.24	0.12					
it	0.24	0.02	-0.06	0.01	-0.07	0.39	0.05	0.39	0.04	0.21				
nl	0.79	0.86	0.29	0.74	0.51	0.03	0.86	0.06	0.13	0.6	0.01			
no	0.22	0.17	0.15	0.09	0.2	0.04	0.08	0.13	0.46	0.14	0.12	0.11		
se	0.51	0.52	0.17	0.45	0.68	0.06	0.25	0.12	0.56	0.17	0.02	0.34	0.47	
uk	0.66	0.72	0.42	0.49	0.53	-0.04	0.59	0.08	0.14	0.4	-0.03	0.74	0.17	0.34
All 13 SG														



**Gray rows hardly help the green rows on balancing wind**

# Frequency distribution of the Generation



Very few hours with more than 50% concurrent generation and few hours with no generation



# Evaluation of the Simulation

## **Simulation period**

- July 2008 – June 2010

## **Target parameters**

- Day ahead Error (traditional single forecast)
- Day ahead Uncertainty ( $EPS_{\max} - EPS_{\min}$ )
- Forecast of day-ahead Error

## **Aggregation**





- Each Country
- Countries scaled up with capacity
- Entire SuperGrid

# Day ahead Forecast Error Statistics - 00UTC forecasts -

no	Country	BIAS	MAE	RMSE	STDV	Capacity [MW]	RMSE [MW]	Gain [MW]
1	IE	-0.16	4.81	6.81	6.81	1412	96	43
2	DE	0.50	3.02	4.66	4.64	25500	1188	232
3	DK	0.00	4.41	6.53	6.53	3200	209	89
4	BE	0.04	4.90	7.53	7.53	642	48	24
5	FR	-0.05	3.04	4.49	4.49	4709	211	35
6	NL	0.05	5.17	7.70	7.70	2775	214	110
7	SE	0.92	3.34	4.79	4.71	1537	74	16
8	UK	-0.51	4.97	6.82	6.80	5089	347	156
9	AVR	0.25	3.57	5.32	5.31	44864	2388	705
10	SG	0.25	2.55	3.75	3.75	44864	1682	0
ratio	SG/SGsum	1.0	0.7	0.7	0.7			
saving		0.5	28.6	29.5	29.3			

Statistical values are in [% of installed capacity] unless otherwise marked

# Day ahead Forecast Error - 00UTC



- SuperGrid generates ~**30% lower error** by aggregation over SuperGrid area

- Large countries with dispersed generation => low error

- Small countries => often higher error

- NL is located in the middle and benefit most





# Day ahead Forecast Error Statistics

## - 06UTC forecasts -

no	Country	BIAS	MAE	RMSE	STDV	Capacity [MW]	RMSE [MW]	Gain [MW]
1	IE	-0.36	4.06	5.83	5.82	1412	82	35
2	DE	0.37	2.54	4.08	4.06	25500	1040	189
3	DK	-0.21	3.79	5.74	5.74	3200	184	77
4	BE	-0.09	4.28	6.80	6.8	642	44	22
5	FR	-0.06	2.65	4.02	4.02	4709	189	32
6	NL	-0.09	4.48	6.86	6.86	2775	190	98
7	SE	0.61	2.76	4.12	4.07	1537	63	12
8	UK	-0.49	4.25	5.97	5.95	5089	304	134
9	AVR	0.14	3.03	4.67	4.66	44864	2097	598
10	SuperGrid	0.14	2.16	3.34	3.34	44864	1498	0
ratio	-	-	0.71	0.71	0.72			
saving	-	-	28.8	28.5	28.3			

Note: forecasts still available before gate closure

# Day ahead Forecast Error - 06UTC



06UTC shows the **same pattern as 00UTC** but with **much lower error (RMSE)**:

- 1% lower error in average
- 0.5% lower error on SuperGrid

Real measurements from each area would confirm the result (tested in DE, DK, IE).


The result will most likely continue to scale with more detailed forecasting.

**A permanent error reduction of 600-700MW is a considerable cost reduction.**

Forecasts still available before gate closure


# Day ahead Forecast Error & Gain from the SuperGrid RMSE [% inst. cap]

00 UTC



SuperGrid RMSE 00 UTC: 3.75%

06 UTC



SuperGrid RMSE 06 UTC: 3.34%

Note: forecasts available before gate closure

A fundamental problem to consider:  
each Inter-Connector provides only 1-way Regulation

**The forecasting process must consider 3 cases to maintain the possibility to exchange imbalances on the SuperGrid:**

- A) Full import** (use lower percentiles or minimum of wind power forecast)
- B) Import and Export** ( use RMSE optimized forecast or P50)
- C) Full export** (use upper percentiles or maximum of wind power forecast)


Forecast Step 1: Determine prices and flow direction with P50 forecast

Forecast Step 2: Select percentile from flow (cannot change flow direction)

**Provides the highest level of grid security, because reserve is kept at a maximum level, but there may be an N-1 interconnector issue to consider in case C .**

# Competition factors within each Price Zone Confirm the use of Percentiles in Forecasting

Wind	Competition	Demand-wind	Preferred error	Wind Forecast choice
Low (A)	Low	High	-	Minimum or P10
Medium (B)	Medium	Medium	unknown	RMSE optimised
High (C)	High	Low	+	Maximum or P90



**Case A:** It is difficult to buy more power in the market, because all cheap generation is in use. The demand peak is short, so the most flexible and cheap Generation is already active

**Case C:** The challenge is to get rid of the power in the market, while many scheduled generators are eager to start especially because this wind peak is short lasting



# How can the SuperGrid balancing be Implemented ?

It is expected that all wind farms sign in, because balancing of single wind farms and **small pools will not be competitive**.

A **central Market Operator** is required (MO) with decision right on all interconnectors and the obligation to get as much wind power sold as is technically feasible ( with successive auctions if required)

Each country will be **payed by MO** based on what MO recover on the market. Each country pay wind farm owners according to the country's own specific incentive scheme and recover any loss locally. There is **no need to harmonize** the national scheme also not for recovery of balancing costs.

MO **handles forecasts transparent to the market with publication** every 6 hours in a easy to use format showing "Demand-intermittent generation" graphically and as percentiles

MO uses a **large number of providers, where each has to forecast for entire SuperGrid**. Only MO knows the weight of each forecast provider.

# Conclusions

- **A 30% reduction of forecast errors** can be expected from the selected central SuperGrid of IE, UK, NL, BE, FR, DE, DK and SE  
=> **more to be gained by the including a North Sea Offshore Grid**
- Correlation of generation suggests **three European clusters** (North, Central, South). France and Sweden divided into two parts and connected respectively to the south and north.
- Use of percentiles in forecasting of wind power ensures that **inter-connectors can be considered permanently available** for exchange of imbalances
- All considerations with respect to competition on the market and grid security factors **suggest the same systematic use of percentiles** in forecasting
- The maximum generation **exceeds only very seldom 60%** of the rated capacity and even more seldom, if all Europe is included

